



LICENCE OF CERTIFICATION

Date of valid edition No:
 2008-05-28 5070

Date of issue Reference
 2008-05-28

Licensee's name and address

Conformity mark covered by license

KWH Pipe Sverige AB
 Däckvägen 12
 506 49 Borås



Information regarding licensee/maker

Licensee's technical officer Ronny Eriksson	Telephone 46 33 23 36 20	Telefax +46 33 12 11 00
	E-mail ronny.eriksson@kwhpipe.se	
Manufacturer KWH Pipe Sverige AB	Place of manufacture Däckvägen 12, Borås	

Product covered by the licence

Type of product Plastics piping systems for the supply of gaseous fuels - Polyethylene (PE)	Standard Normative document EN 1555:2002	Specific rules INSTA SBC 1555
--	--	--------------------------------------

Specification of product

PE80 Pipes with a maximum operating pressure MOP of 5 bars.

SDR class	17	11
Nominal outside diameter	16 - 225 mm	16 - 225 mm
Size group	1, 2	1, 2

PE100 Pipes with a maximum operating pressure MOP of 10 bars.

SDR class	17	11
Nominal outside diameter	16 - 630 mm	16 - 500 mm
Size group	1, 2, 3	1, 2, 3

Confidential information according to the enclosure

The licensee above is hereby given permission to use the INSTA-CERT mark on or in connection with products, which fulfil the requirements of the standard or the normative document specified above (what is said in this document about INSTA-CERT mark will also be valid for marks defined in relevant SBC). The certification licence is valid on the condition that the licensee complies with the "General rules for certification by partners of INSTA-CERT" (GRC) and the specific rules applying to certification of products of the type mentioned. The licensee is obliged to indemnify INSTA-CERT partners of any claim for damages or any other expenses to which partners may become liable as a result of injuries caused by a product manufactured or sold by the licensee. This also applies to defective or faulty products.

The licence is valid for one calendar year and is automatically renewed for one year at a time, unless the licensee or member of INSTA-CERT gives at least three months notice to the contrary.

The licence is not transferable.

MEMBER OF INSTA-CERT

SP Sveriges Tekniska Forskningsinstitut

Lennart Månsson



LICENCE OF CERTIFICATION

Confidential appendix 1

Date of valid edition No:
2008-05-28 5070

Date of issue Reference
2008-05-28

The tables below shows the approved combinations of sizes, SDR classes and raw materials.

PE80 INEOS Eltex TUB 172 Pipes with a maximum operating pressure MOP of 5 bars.

SDR class	17	11
Nominal outside diameter Size group	16 - 225 mm 1, 2	16 - 225 mm 1, 2

PE100 BorSafe HE3490-LS Pipes with a maximum operating pressure MOP of 10 bars.

SDR class	17	11
Nominal outside diameter Size group	16 - 630 mm 1, 2, 3	16 - 500 mm 1, 2, 3